



CITY OF SAN MARCOS ENGINEERING DIVISION

AN APPLICANT'S GUIDE TO PROCEDURES FOR:

MASTER TRAILS TYPICAL CROSS SECTION

1 Civic Center Dr., San Marcos, CA 92069-2918 (760) 744-1050 FAX (760) 591-4135

ASPHALTIC CONCRETE PATH

1. 2" MINIMUM LAYER A.C. PAVING
2. 2 x 4 RDWD. HDR FLUSH W/TOP OF AC PAVING AND FINISH GRADE OR OPTIONAL 6" HIGH BY 6" WIDE PCC MOW CURB.
3. 2 X 4 RDWD. STAKE 18"L. @ 4' O.C. MAX AND @ CORNERS – NAIL TO HEADER W/ONE NAIL @ EACH SIDE.
4. 4" MIN. LAYER COMPACTED CLASS II AGGREGATE PER SOILS ENG – EXTEND EDGE 6" MIN.
5. 90% MIN. COMPACTED SUB-GI
6. FINISH GRADE.

NOTES:

1. INSTALL SOIL STERILANT PER MFRS. REC. @ SUB-GRADE.
2. 2% MIN. CROSS SLOPE
10% MAX. LONG SLOPE

